

Emissionsdaten Bio- und Holzwerkstoffwerk Zapfendorf

3. Quartal 2022

Stoff	Monatsmittelwert	Grenzwert Tagesmittel	Einhaltung der Tagesmittelwerte in %	Einhaltung der Halbstundenmittelwerte in %
Juli 2022				
HCl	mg / m3	2,61	10	100
CO	mg / m3	36,15	50	100
SO2	mg / m3	13,85	50	100
NOX	mg / m3	191,14	200	100
Staub	mg / m3	0,05810	10	100
Cges	mg / m3	0,00852	10	100
NH3	mg / m3	0,0	30	100
August 2022				
HCl	mg / m3	1,47	10	100
CO	mg / m3	35,59	50	100
SO2	mg / m3	18,12	50	100
NOX	mg / m3	190,73	200	100
Staub	mg / m3	0,0	10	100
Cges	mg / m3	0,00825	10	100
NH3	mg / m3	0,0	30	100
September 2022				
HCl	mg / m3	1,83	10	100
CO	mg / m3	32,38	50	100
SO2	mg / m3	17,97	50	100
NOX	mg / m3	189,95	200	100
Staub	mg / m3	0,0	10	100
Cges	mg / m3	0,01460	10	100
NH3	mg / m3	0,0	30	100